

**PORTABLE APPLIANCE TEST
REGISTER & REPORT**

Of

St Cleer Sports Pavilion

Carried out by
CIC Safety Services
Tor View School Rd, Pensilva,
Liskeard Cornwall.
01579 362292 / 07833903374
Cert No. 310108/2377-12/054977/FVP3857/E/06/11/86

November 2018



CIC SAFETY SERVICES

Tor view, School rd, Pensilva, Liskeard
☎ 01579/383995 or 07833903374
cicsafetyservices@outlook.com

Institute of Occupational Safety and Health Technician member.
National Examining board in Occupational Health Gen. Certificate.
Construction Industry Training Board Reg. Instructor. City & Guild D32/33
Member of the Lantra Professional Register.



12th November 2018

Dear Roni,

I submit the following report after concluding the test and inspection of the Portable Appliances for St Cleer Parish Council, Sports Pavilion.

The register was compiled, and items were numbered 8424 to 8443.
A total of 20 items were tested.

Generally, the appliances were in good order. None of the appliances required any repairs, and none failed testing.
Pass stickers have been placed either on the plug where possible, or on the appliances themselves.

Also enclosed is a register of appliances in compliance with The Code of Practice for In-service Inspection and Testing of Portable Appliances.

We would suggest retest and inspection within 12 months. Unless otherwise notified we will send a non-obligatory reminder one month prior.

If you have any queries on these issues, please contact us on either number above.

Yours Sincerely

Sarah Prout

CIC Safety Services

List of tests

created at: 16/11/2018

Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Councill 12/11/2018	Sports Pavilion 1	KITCHEN yes No	8424 Sarah Prout	CATERLITE WATER HEATER FLUKE 6500	131	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes
		Earth bond resistance 25A AC		max 0.1 Ohm	0.07 Ohm	yes
		Insulation resistance 500 V [1,0 MOhm]		min 1 MOhm	199.4 MOhm	yes
		Cable test L-N				yes
		Differential current [3,5 mA]		max 3.5 mA	0.08 mA	yes
		Load power		max 3 kVA	1.742 kVA	yes
		Load current		max 13 A	7.5 A	yes
Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Councill 12/11/2018	Sports Pavilion 2	KITCHEN yes No	8425 Sarah Prout	SWAN KETTLE FLUKE 6500	131	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes
		Earth bond resistance 25A AC		max 0.1 Ohm	0.07 Ohm	yes
		Insulation resistance 500 V [1,0 MOhm]		min 1 MOhm	>299.9 MOhm	yes
		Cable test L-N				yes
		Differential current [3,5 mA]		max 3.5 mA	0.10 mA	yes
		Load power		max 3 kVA	2.005 kVA	yes
		Load current		max 13 A	8.7 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 3	KITCHEN yes No	8426 Sarah Prout	ASDA SANDWICH TOASTER FLUKE 6500	131

Loc. - No.	Test step	Limit	Value	Passed
	Visual test of mains cable and appliance			yes
	Earth bond resistance 25 A AC	max 0.4 Ohm	0.03 Ohm	yes
	Insulation resistance 500 V [1,0 MOhm]	min 1 MOhm	>299.9 MOhm	yes
	Cable test L-N			yes
	Differential current [3,5 mA]	max 3.5 mA	0.03 mA	yes
	Load power	max 3 kVA	0.730 kVA	yes
	Load current	max 13 A	3.1 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 4	KITCHEN yes No	8427 Sarah Prout	TECHNIKA STEREO FLUKE 6500	234

Loc. - No.	Test step	Limit	Value	Passed
	Visual test of mains cable and appliance			yes
	Insulation resistance 500 V [2,0 MOhm]	min 2 MOhm	>299.9 MOhm	yes
	Cable test L-N			yes
	Differential current	max 0.25 mA	0.01 mA	yes
	Load power	max 3 kVA	0.003 kVA	yes
	Load current	max 13 A	0.0 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Council 12/11/2018	Sports Pavilion 5	KITCHEN yes No	8428 Sarah Prout	REMINGTON HAIR DRYER FLUKE 6500	234
Loc. - No.	Test step	Limit	Value	Passed	
	Visual test of mains cable and appliance			yes	
	Insulation resistance 500 V [2,0 MOhm]	min 2 MOhm	>299.9 MOhm	yes	
	Cable test L-N			yes	
	Differential current	max 0.25 mA	0.08 mA	yes	
	Load power	max 3 kVA	1.703 kVA	yes	
	Load current	max 13 A	7.3 A	yes	

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Council 12/11/2018	Sports Pavilion 6	STORE yes No	8429 Sarah Prout	50M EXTN REEL FLUKE 6500	Basis type
Loc. - No.	Test step	Limit	Value	Passed	
	Visual test of mains cable and appliance			yes	

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Council 12/11/2018	Sports Pavilion 7	KITCHEN yes No	8430 Sarah Prout	ZANUSSI FRIDGE FLUKE 6500	131
Loc. - No.	Test step	Limit	Value	Passed	
	Visual test of mains cable and appliance			yes	
	Earth bond resistance 25A AC	max 0.1 Ohm	0.09 Ohm	yes	
	Insulation resistance 500 V [1,0 MOhm]	min 1 MOhm	>299.9 MOhm	yes	

Loc. - No.	Test step	Limit	Value	Passed
	Cable test L-N			yes
	Differential current [3,5 mA]	max 3.5 mA	0.02 mA	yes
	Load power	max 3 kVA	0.012 kVA	yes
	Load current	max 13 A	0.0 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 8	STORE yes No	8431 Sarah Prout	MORPHY RICHARDS IRON FLUKE 6500	131

Loc. - No.	Test step	Limit	Value	Passed
	Visual test of mains cable and appliance			yes
	Earth bond resistance 25A AC	max 0.1 Ohm	0.05 Ohm	yes
	Insulation resistance 500 V [1,0 MOhm]	min 1 MOhm	>299.9 MOhm	yes
	Cable test L-N			yes
	Differential current [3,5 mA]	max 3.5 mA	0.02 mA	yes
	Load power	max 3 kVA	0.000 kVA	yes
	Load current	max 13 A	0.0 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 9	STORE yes No	8432 Sarah Prout	KARCHER HOOVER FLUKE 6500	234

Loc. - No.	Test step	Limit	Value	Passed
	Visual test of mains cable and appliance			yes
	Insulation resistance 500 V [2,0 MOhm]	min 2 MOhm	>299.9 MOhm	yes
	Cable test L-N			yes
	Differential current	max 0.25 mA	0.05 mA	yes
	Load power	max 3 kVA	1.198 kVA	yes

Loc. - No.	Test step	Limit	Value	Passed
	Load current	max 13 A	5.1 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 10	KITCHEN yes No	8433 Sarah Prout	SAMSUNG MICROWAVE FLUKE 6500	131

Loc. - No.	Test step	Limit	Value	Passed
	Visual test of mains cable and appliance			yes
	Earth bond resistance 25A AC	max 0.1 Ohm	0.03 Ohm	yes
	Insulation resistance 500 V [1,0 MOhm]	min 1 MOhm	>299.9 MOhm	yes
	Cable test L-N			yes
	Differential current [3,5 mA]	max 3.5 mA	0.25 mA	yes
	Load power	max 3 kVA	0.003 kVA	yes
	Load current	max 13 A	0.0 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 11	STORE yes No	8434 Sarah Prout	CONVECTOR HEATER FLUKE 6500	131

Loc. - No.	Test step	Limit	Value	Passed
	Visual test of mains cable and appliance			yes
	Earth bond resistance 25A AC	max 0.1 Ohm	0.07 Ohm	yes
	Insulation resistance 500 V [1,0 MOhm]	min 1 MOhm	>299.9 MOhm	yes
	Cable test L-N			yes
	Differential current [3,5 mA]	max 3.5 mA	0.09 mA	yes
	Load power	max 3 kVA	1.911 kVA	yes
	Load current	max 13 A	8.2 A	yes

Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Council 12/11/2018	Sports Pavilion 12	STORE yes No	8435 Sarah Prout	BELDRAY HEATER FLUKE 6500	131	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes
		Earth bond resistance 25A AC		max 0.1 Ohm	0.03 Ohm	yes
		Insulation resistance 500 V [1,0 MOhm]		min 1 MOhm	>299.9 MOhm	yes
		Cable test L-N				yes
		Differential current [3,5 mA]		max 3.5 mA	0.05 mA	yes
		Load power		max 3 kVA	1.145 kVA	yes
		Load current		max 13 A	4.9 A	yes
Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Council 12/11/2018	Sports Pavilion 13	STORE yes No	8436 Sarah Prout	EPSON PRINTER FLUKE 6500	233	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes
		Insulation resistance 500 V [2,0 MOhm]		min 2 MOhm	>299.9 MOhm	yes
Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Council 12/11/2018	Sports Pavilion 14	FUNCTION ROOM yes No	8437 Sarah Prout	LG TV FLUKE 6500	233	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes

Loc. - No.	Test step	Limit	Value	Passed	
	Insulation resistance 500 V [2,0 MOhm]	min 2 MOhm	>299.9 MOhm	yes	
Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 15	CCTV CUPBOARD yes No	8438 Sarah Prout	4 WAY EXTN FLUKE 6500	Basis type
Loc. - No.	Test step	Limit	Value	Passed	
	Visual test of mains cable and appliance			yes	
Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 16	CCTV CUPBOARD yes No	8439 Sarah Prout	CCTV MONITOR FLUKE 6500	Basis type
Loc. - No.	Test step	Limit	Value	Passed	
	Earth bond resistance 10 A AC	max 0.1 Ohm	0.03 Ohm	yes	
	Insulation resistance 500 V [2,0 MOhm]	min 2 MOhm	>299.9 MOhm	yes	
	Cable test L-N			yes	
Client name	Site name	Location name	Appliance no.	Appliance name	Type
Test date	Test no.	Passed	Inspector	Test instrument	
Order No.	Test reason	Intermediate test	Remark		
St Cleer Parish Councill 12/11/2018	Sports Pavilion 17	CCTV CUPBOARD yes No	8440 Sarah Prout	CAMERA 2 FLUKE 6500	233
Loc. - No.	Test step	Limit	Value	Passed	
	Visual test of mains cable and appliance			yes	
	Insulation resistance 500 V [2,0 MOhm]	min 2 MOhm	>299.9 MOhm	yes	

Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Council 12/11/2018	Sports Pavilion 18	CCTV CUPBOARD yes No	8441 Sarah Prout	CAMERA 1 FLUKE 6500	233	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes
		Insulation resistance 500 V [2,0 MOhm]		min 2 MOhm	>299.9 MOhm	yes
Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Council 12/11/2018	Sports Pavilion 19	CCTV CUPBOARD yes No	8442 Sarah Prout	CCTV RECORDER FLUKE 6500	233	
	Loc. - No.	Test step		Limit	Value	Passed
		Visual test of mains cable and appliance				yes
		Insulation resistance 500 V [2,0 MOhm]		min 2 MOhm	>299.9 MOhm	yes
Client name	Site name	Location name	Appliance no.	Appliance name	Type	
Test date	Test no.	Passed	Inspector	Test instrument		
Order No.	Test reason	Intermediate test	Remark			
St Cleer Parish Council 12/11/2018	Sports Pavilion 20	CCTV CUPBOARD yes No	8443 Sarah Prout	CAMERA 3 & 4 FLUKE 6500	Basis type	
	Loc. - No.	Test step		Limit	Value	Passed
		Earth bond resistance 10 A AC		max 0.1 Ohm	0.04 Ohm	yes
		Insulation resistance 500 V [2,0 MOhm]		min 2 MOhm	>299.9 MOhm	yes
		Cable test L-N				yes



CIC SAFETY SERVICES

Certificate of Portable Appliance in Service Testing

For

St Cleer Sports Pavilion

This is to certify that

The Portable Electrical Appliances of the above premises have been tested in compliance with the Electricity at Work regulations 1989, and with reference to the Code of Practice for In Service Inspection and Testing of Electrical Equipment.

Issued on **12/11/2018**

For a period of **12** Months.

Certain appliances according to type and use may need more frequent inspection and testing. Users should refer to Code of Practice for in Service Testing and Inspection of Electrical Equipment.

Certificate no. **P2369**